

श्रीरामपूर नगरपरिषद, श्रीरामपूर

नगरपरिषद कार्यालय, श्रीरामपूर - ४१३७०९, जि.अहमदनगर, फोन क्रमांक २२२१५४, २२२१५५, २२२७३१, फॅक्स: २२३०००

Website: www.shrirampurmc.gov.in

जा.क्रमांक. ८२२०२१-१३६३

दिनांक :- ०७/०४/२०२१

प्रति,
अशोक आयडियल स्कुल,
प्रगतीनगर, अशोकनगर फाटा, ता. श्रीरामपूर, जि. अहमदनगर

विषय:- अग्निशमन ना-हरकत प्रमाणपत्र बाबत.
संदर्भ:- आपला दि.०८/१०/२०२० रोजीचा अर्ज

महोदय,

उपरोक्त संदर्भिय विषयानुसार कळविणेत येते की, आपला गट नं. ३१/५, प्रगतीनगर, अशोकनगर फाटा, शिरसगाव येथे शैक्षणिक कामासाठी अग्निशमन ना हरकत प्रमाणपत्र आवश्यक आहे. संदर्भिय अर्जदार यांनी निरो फायर सर्व्हिसेस औरंगाबाद या खाजगी संस्थेमार्फत सदर नमूदीत जागेत महाराष्ट्र अग्नि प्रतिबंधक व जीव संरक्षक उपाययोजना करणेत आलेल्या आहेत. त्या पुढील प्रमाणे.

१) ए.बी.सी. टाईप ६ कि.ग्र.चे तीन फायर एक्सटीग्युशर बसविलेले आहेत.


उपरोक्त प्रमाणे अग्नि प्रतिबंधक यंत्रणा सदर इमारतीत बसविणेत आलेली आहे. अग्नि प्रतिबंधक उपाययोजना महाराष्ट्र अग्नि प्रतिबंधक व जीव संरक्षक उपाययोजना २००६ अनव्ये अग्निशमन ना हरकत प्रमाणपत्र देण्यात येत आहे.

सदरचा ना हरकत प्रमाणपत्र दि.०६/०४/२०२२ पूर्वी नुतनीकरण करणे बंधनकारक राहिल.



मुख्याधिकारी

श्रीरामपूर नगरपरिषद, श्रीरामपूर



Translated from Marathi



MRF
TRANSLATION
Reg.No. VYAS/A/BAD/133/31431/09

SHRIRAMPUR MUNICIPAL COUNCIL, SHRIRAMPUR

Municipal Office, Shrirampur 413709, Dist. Ahmednagar, Ph. No.
222154, 222155, 222731, Fax 223000

Website: www.shrirampurmc.gov.in

Outward No. 82202/-1363

Date; 07/04/2021

To,
Ashok Ideal School
Pragati Nagar, Ashok Nagar Phata
Tq. Shrirampur, Dist. Ahmednagar

Sub: Regarding Fire NOC

Ref: Your application dated 08/10/2020

Sir,

This is to inform you that, you require Fire NOC for Educational purpose in respect of land at Gut No. 31/5, Pragati Nagar, Ashok Nagar Phata, Shirasgaon. The applicant has installed following fire prevention and life saving system through a private firm Nero Fire Services, Aurangabad.

1) A.B.C. type 6 Kg. 3 fire extinguishers

The above fire prevention equipments are installed in the building. Hence this Fire NOC is given as per Maharashtra Fire Prevention Measurements Act, 2006

It would be mandatory to renew this NOC before 06/04/2022.


Round Office seal

Sd/-xx

Chief Officer

Translated by

Shrirampur Municipal Council, Shrirampur


Sk. Kasim Hussain
(B.Com. DSM)

BEFORE ME


Sunil A. Shelke

Notary, Govt. of India

